STATE OF TEXAS WELL REPORT for Tracking #161040

Owner: MIKE SHELLMAN Owner Well #: No Data

Address: P. O. BOX 1287 Grid #: 68-07-2

SAN MARCOS, TX 78667

Well Location: 401 FISCHER STORE RD.

Latitude: 29° 59' 56" N

WIMBERLEY, TX 78676 Longitude: 098° 12' 13" W

Well County: Hays Elevation: No Data

Type of Work: New Well Proposed Use: Domestic

Drilling Start Date: 10/6/2008 Drilling End Date: 10/6/2008

 Diameter (in.)
 Top Depth (ft.)
 Bottom Depth (ft.)

 Borehole:
 9
 0
 50

6.5 50 250

Drilling Method: Air Rotary

Borehole Completion: CASED

Annular Seal Data:

Top Depth (ft.)

Bottom Depth (ft.)

Description (number of sacks & material)

6 VOLCLAY

0 50 7 CEMENT

Seal Method: Slurry Distance to Property Line (ft.): N/A

Sealed By: **Driller**Distance to Septic Field or other concentrated contamination (ft.): **N/A** 

Distance to Septic Tank (ft.): No Data

Method of Verification: WELL DRILLED

**FIRST** 

Surface Completion: Surface Sleeve Installed

Water Level: No Data

Packers: 4 BURLAP, PVC, RUBBER 50', 130', 150', 230'

Type of Pump: Submersible

Well Tests: Jetted Yield: 25-30 GPM

Water Quality:

Strata Depth (ft.)

Water Type

MIDDLE TRINITY

Chemical Analysis Made: No

Did the driller knowingly penetrate any strata which contained injurious constituents?: **No** 

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the

driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in

the report(s) being returned for completion and resubmittal.

Company Information: CENTRAL TEXAS DRILLING, INC.

2520 HWY. 290 WEST

**DRIPPING SPRINGS, TX 78620** 

Driller Name: AARON GLASS License Number: 4227

Comments: No Data

## Lithology: DESCRIPTION & COLOR OF FORMATION MATERIAL

## Casing: BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description
0-1 TOP SOIL
1-21 CALICHE W/GRAVEL
21-24 BLUE GRAY LIMESTONE
24-55 GRAY LIMESTONE
55-140 GRAY/TAN LIMESTONE
140-170 GRAY LIMESTONE
170-195 TAN LIMESTONE
195-220 BROWN LIMESTONE
220-230 GRAY/TAN/BROWN LIMESTONE
230-240 GRAY CLAY STRIPS
240-245 TAN LIMESTONE
245-250 GRAY LIMESTONE W/HAMMIT
CLAY

Dia. (in.) New/Used Type Setting From/To (ft.)

5" OD N SDR17 PVC +3 TO 250

5" OD N SDR17 PVC SLOT 170 TO 250 .032

## IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation P.O. Box 12157 Austin, TX 78711 (512) 334-5540